



Variable Refrigerant Flow (VRF)

Project Information Form

For Commercial, Industrial, and Agricultural Applications

Instructions: Complete this form and submit it to EWEB at ems.answers@eweb.org.

BUSINESS AND SITE INFORMATION

| | |
|---|---|
| Customer Name | |
| Installation Address (Street, City, State, Zip) | |
| Customer Phone Number | |
| New Construction (Y,N): ____ | Square Footage: _____ |
| Building type (Please check one) | <input type="checkbox"/> Office <input type="checkbox"/> Retail <input type="checkbox"/> Grocery <input type="checkbox"/> Lodging <input type="checkbox"/> Warehouse <input type="checkbox"/> Food Service <input type="checkbox"/> Hospital <input type="checkbox"/> School <input type="checkbox"/> Residential Care <input type="checkbox"/> Assembly <input type="checkbox"/> Other (describe): _____ |

PROJECT INFORMATION

| | |
|--|--|
| VRF manufacturer | |
| VRF model | |
| Outdoor unit cooling capacity (tons) | |
| Installed cost (per attached invoice) | |
| Order/purchase date (per attached invoice) | |

The installed VRF system must meet EWEB efficiency requirements as shown below.

The following documents must be submitted with this form:

1. AHRI Certificate documenting that the efficiency requirements have been met
2. The installation contractor invoice showing order/purchase date and installed cost

Additional terms, conditions, and requirements may apply.

Effective date: October 1, 2023

| EQUIPMENT SIZE (COOLING CAPACITY; BTU/H) | MODE | SUB-CATEGORY OR RATING CONDITION | EFFICIENCY REQUIREMENT |
|--|---------|--|------------------------|
| ≥65,000 and <135,000 | Heating | VRF Multi-split System 47°F db/43°F wb Outdoor Air | 3.7 COP |
| ≥135,000 and <240,000 | Heating | VRF Multi-split System 47°F db/43°F wb Outdoor Air | 3.5 COP |
| ≥240,000 | Heating | VRF Multi-split System 47°F db/43°F wb Outdoor Air | 3.5 COP |